

Understanding Fixed and Portable Firefighting Equipment


An owner's guide to extinguishing media, protected-space systems and first response

Firefighting equipment must match the fuel, location, access and stage of the incident.

A correct extinguisher in the wrong place or an unsealed fixed system may not control the fire.

Absolute Marine

Commercial thinking for private cruising.



MATCH | DEPLOY | CONTROL

GUIDE OVERVIEW

What fixed and portable firefighting equipment is designed to do

Portable equipment provides immediate first response and protects escape. Fixed systems distribute an extinguishing agent through a protected space when direct entry is unsafe or ineffective.

SCOPE

This guide covers common portable extinguishers, fire blankets and fixed machinery-space systems including gaseous, aerosol, water-mist and other approved agents. Agent classifications and legal requirements vary by region and vessel; the approved fire plan and service documentation remain authoritative.

By the end of this guide, you should be able to:

- Match the equipment and agent to the likely fuel, space and electrical condition.
- Identify portable units, fixed cylinders, release stations, nozzles, alarms, shutdowns and protected boundaries.
- Recognise pressure loss, corrosion, obstructed access, wrong agent, disabled release and enclosure leakage.
- Understand why evacuation, fuel or ventilation shutdown and boundary control are central to fixed-system use.
- Ask better questions during purchase, survey, servicing, drills and offshore preparation.

CORE PRINCIPLE

The safest equipment is the one that can be reached without moving toward the fire, is suitable for the hazard and can be used while maintaining a clear escape route.


Safety

Fire and extinguishing agents can create toxic, asphyxiation, visibility and pressure hazards. Gaseous fixed systems should not be released until the protected space is evacuated and the vessel procedure has been followed. Never re-enter solely because flames are no longer visible.

SYSTEM ARCHITECTURE

From detection and agent selection to controlled extinguishment

Successful response combines early detection, the right extinguishing medium, safe access, fuel and ventilation control, adequate agent application and monitoring for re-ignition.



Layer	Purpose	Owner focus
Detection and warning	Creates time to choose an appropriate response before conditions worsen.	Know detector zones, manual alarms, local signs and escape routes.
Portable equipment	Allows rapid attack on a small, accessible fire while preserving escape.	Agent type, rating, reach, duration, mounting and user familiarity.
Fixed suppression	Applies a designed concentration or water distribution to a protected volume.	Cylinder condition, agent quantity, nozzles, release, alarms and enclosure integrity.
Shutdown and containment	Stops fuel and ventilation and closes openings to prevent escalation or agent loss.	Confirm physical closure and understand what essential services remain.
Boundary cooling and backup	Protects adjacent spaces and controls re-ignition after initial suppression.	Fire-main availability, portable backup and thermal monitoring.
Crew decision-making	Determines when to attack, withdraw, release fixed agent or abandon the space.	Training, communications, PPE and a clear threshold for escalation.

EXTINGUISHERS PROTECT ESCAPE FIRST	Portable firefighting should not encourage a crew member to remain in a space that is becoming untenable. Keep the exit behind you and withdraw early.
---------------------------------------	--

MAIN COMPONENTS

What owners should be able to identify

A fire-control plan should show each portable extinguisher, blanket, fixed cylinder or generator, release station, alarm, distribution pipe or nozzle, ventilation or fuel shutdown and service date.

PORTABLE UNITS

Water, foam, powder, CO2 or approved specialist agent

FIXED AGENT

Cylinder or generator sized for protected volume

RELEASE / ALARM

Manual or automatic action with warning and delay

SPACE / SHUTDOWNS

Nozzles, enclosure, fuel and ventilation controls

Agent names and colours vary by jurisdiction; identify equipment from its current label and approved documentation.

Component or area	Why it matters	Owner focus
Portable extinguishers	Provide immediate agent at the point of use.	Correct type or rating, location, pressure or weight, pin or seal, hose and service status.
Fire blankets	Smother small cooking or clothing fires and protect hands while covering.	Accessible position, intact container, correct size and user familiarity.
Fixed agent container or generator	Stores or creates the extinguishing medium for the protected space.	Agent mass or pressure, cylinder corrosion, mounting, temperature and service life.
Distribution pipework and nozzles	Delivers the designed agent quantity and pattern.	No blockage, damage, paint, obstruction or unapproved alteration.
Release station and pre-alarm	Initiates discharge and warns personnel to evacuate.	Safe external location, guards or seals, instructions, delay and fault indication.
Fuel, ventilation and electrical interlocks	Limit fire energy and retain agent concentration.	Demonstrated shutdown, damper closure and essential-system consequences.

LOCATION IS PART OF SUITABILITY

An extinguisher mounted beside the likely fire may be unreachable. Units should be approached from a safe direction and positioned near exits or access routes as the fire plan requires.

AGENTS AND APPLICATIONS

Matching extinguishing media to the hazard

No agent is ideal for every fire. Selection should consider the fuel, electrical state, occupied-space risk, contamination, cooling requirement, re-ignition potential and approved vessel design.

WATER / MIST

Strong cooling for suitable solid combustibles

FOAM / WET AGENT

Controls suitable liquid or cooking-oil surface fires

DRY POWDER

Rapid knockdown but poor visibility and residue

CO2 / CLEAN AGENT

Non-conductive suppression with atmosphere hazard

Always follow the extinguisher label and local fire classification; de-energise electrical equipment where safe.

Area	What matters	Owner focus
Water or water mist	Cools fuel and structure; specialist mist systems may be approved for wider hazards.	Do not use ordinary water where it can spread burning liquids or create electrical shock.
Foam	Forms a blanket over suitable flammable-liquid surfaces and can provide cooling.	Correct foam type, application method, environmental restrictions and compatibility.
Dry powder	Interrupts combustion quickly across several fire types.	Limited cooling, severe visibility or respiratory impact and contamination of machinery or electronics.
Carbon dioxide	Displaces oxygen locally and leaves no residue.	Short discharge, re-ignition risk, poor outdoor effectiveness and serious asphyxiation hazard.
Clean gaseous agent	Designed concentration suppresses fire with limited residue.	Protected volume, leakage, agent availability, exposure limits and service support.
Cooking-oil or battery-specific hazards	May require specialist wet agent, cooling or manufacturer emergency guidance.	Do not assume a general extinguisher will stop thermal runaway or deep-seated hot oil.

KNOCKDOWN IS NOT EXTINCTION

CO2 and powder can remove visible flame without cooling hot fuel or structure. Re-ignition control and boundary cooling may still be required.

OPERATION AND CONTROL

Using portable equipment and releasing fixed systems

The crew should raise the alarm first, assess escape, remove fuel and ventilation where appropriate, select the correct agent and withdraw before heat or smoke make the route unsafe.

ALARM / ESCAPE

Call assistance and keep a clear withdrawal route

SELECT AGENT

Read label and match the likely fuel or electrical state

CONTROL ENERGY

Stop fuel, cooking, power and ventilation if safe

APPLY / RELEASE

Use correct distance and approved fixed-system sequence

MONITOR / WITHDRAW

Watch heat, re-ignition and boundary spread

Area	What matters	Owner focus
Portable extinguisher approach	Approach only if the fire is small, the correct agent is available and escape remains clear.	Position between fire and exit rather than allowing the fire to block retreat.
Discharge technique	Aim and sweep or apply according to the unit and fuel type.	Avoid standing too close, dispersing burning liquid or losing visibility.
Fire blanket	Switch off heat if safe and place the blanket over the fire without throwing it.	Do not remove immediately; avoid leaning over the burning container.
Fixed-system preparation	Raise alarm, stop machinery, fuel and fans, close dampers and confirm evacuation.	Do not release into an occupied or unsealed space except under the approved emergency plan.
Fixed-system release	Operate the correct station and confirm discharge or status.	Avoid reopening doors, hatches or ventilation before hold time and assessment.
Post-discharge control	Monitor temperature, smoke, boundaries and possible re-ignition.	Do not assume the space is safe to enter because alarms reduce or flames disappear.


**ONE EXTINGUISHER
HAS LIMITED DURATION**

Portable units discharge quickly. Decide before activation where to aim, how to withdraw and what backup equipment is available.

DEPENDENCIES AND RESILIENCE

What can defeat apparently complete fire protection

Fixed and portable systems rely on access, detection, correct agent quantity, protected-space boundaries, shutdowns, crew awareness and current service support.



A fixed system is designed for a particular protected volume and opening condition; later modifications can invalidate it.

Area	What matters	Owner focus
Protected-space volume	Added enclosures, tanks or machinery can change the required agent quantity.	Confirm the current volume matches the approved design.
Ventilation and openings	Fans, dampers, doors, cable transits and drains can leak agent.	Functional shutdown and enclosure integrity should be demonstrated.
Detection and release power	Loss of batteries, panel or wiring may remove warning or automatic action.	Independent or manual release and fault monitoring are important.
Fuel and electrical isolation	Continuing fuel spray, hot machinery or live circuits can overwhelm suppression.	Coordinate emergency shutdowns and preserve only necessary emergency power.
Portable-equipment access	Refit joinery, furnishings or stored gear can obstruct units.	Approach route, signage and mounting should remain obvious.
Agent availability and regulation	Some agents, cylinders or service parts become difficult to support.	Confirm legal servicing, refill and replacement in the intended cruising region.

THE SPACE IS PART OF THE FIXED SYSTEM

Nozzle placement and agent quantity assume doors, dampers and penetrations are in the designed condition. A new vent or open access hatch can reduce effectiveness.

MONITORING AND ALARMS

Knowing whether equipment is ready before the fire

Portable units provide mainly visual evidence. Fixed systems may include pressure switches, panel faults, bottle weight or pressure indication, release status and supervision of shutdowns.

PORTABLE CONDITION
Pressure, weight, pin, seal and physical damage

FIXED AGENT
Cylinder pressure or mass, temperature and mounting

SYSTEM STATUS
Release circuit, panel, nozzles and faults

SPACE READINESS
Detectors, shutdowns and enclosure condition

A service label shows a visit occurred; it does not replace owner inspection or proof of integrated operation.

Observation	What it may indicate	Owner response
Gauge outside service range	Leakage, temperature effect, discharged unit or damaged valve.	Remove from reliance and arrange competent service or replacement.
Cylinder weight or pressure declining	Agent loss, corrosion or valve leakage.	Compare with manufacturer limits and service records.
Extinguisher obstructed or missing	Poor housekeeping, refit relocation or use without replacement.	Restore correct type and location immediately and update fire plan.
Fixed-system panel fault	Open circuit, low supply, disabled zone, release fault or detector problem.	Treat protection as degraded and investigate promptly.
Release seal or pin damaged	Tampering, accidental partial operation or maintenance not restored.	Inspect complete release path and confirm cylinder status.
Shutdown or damper feedback incomplete	Interlock or actuator fault means the space may not retain agent.	Do not assume the fixed system is fully effective until repaired.

CHECK THE ACTUAL CYLINDER OR CARTRIDGE

A green control-panel light may not prove agent quantity, valve condition, nozzle integrity or protected-space suitability.

FAILURE AWARENESS

Common weaknesses and warning signs

Firefighting equipment can look reassuring while being unsuitable, inaccessible, discharged, corroded, incorrectly serviced or no longer matched to the protected space.

WRONG AGENT

Equipment does not match likely fuel or location

LOST AGENT

Low pressure, leakage or expired service

BLOCKED DELIVERY

Hose, nozzle or pipe is damaged or obstructed

FAILED CONTAINMENT

Openings or shutdowns allow fire and agent to escape

The first failure may be human: the correct equipment cannot be identified or reached under smoke and stress.

Failure or evidence	Possible cause	Why it matters
Portable extinguisher will not discharge	Low pressure, blocked hose, corroded valve, pin or seal problem or internal compaction.	The first attack option is lost while the fire grows.
Agent is unsuitable for the fuel	Incorrect selection, relocation or changed machinery or galley hazard.	Fire can spread, reignite or create electrical or chemical danger.
Fixed cylinder has leaked or been isolated	Valve, pressure, weight, service or maintenance position not recognised.	The protected space receives insufficient agent.
Nozzle or pipework obstructed	Paint, corrosion, debris, refit work or damaged tubing.	Agent distribution is uneven or incomplete.
Ventilation or fuel shutdown fails	Damper, fan, valve or interlock defect.	Oxygen and fuel continue feeding the fire and agent is diluted.
Crew release the system too late	Unclear decision threshold, poor alarms or attempted entry delays evacuation.	Conditions become unsurvivable and equipment damage escalates.

DO NOT NORMALISE CHANGE	An extinguisher that is present but unfamiliar, unsuitable or unreachable should not be counted as dependable protection.
--------------------------------	---

EMERGENCY RESPONSE

Choosing between first attack, withdrawal and fixed-system release

The response should be proportionate to fire size, smoke, heat, agent suitability and escape. A small accessible fire may be attacked; a machinery-space fire may require immediate closure, shutdown and fixed suppression.



Situation or stage	Immediate thinking	Avoid
Small accessible fire	Use the correct portable unit while maintaining escape and calling support.	Fighting alone, turning your back on the exit or continuing after one unit is exhausted.
Galley cooking fire	Turn off heat if safe and use blanket or approved wet agent.	Water on burning oil or carrying the pan through the vessel.
Electrical equipment fire	De-energise where safe and use a suitable non-conductive agent.	Touching equipment or using unsuitable water while it remains energised.
Machinery-space fire	Stop fuel and fans, evacuate, seal the space and release fixed agent per fire plan.	Opening doors repeatedly or entering without suitable firefighting capability.
Battery or specialist fire	Follow battery or equipment manufacturer emergency guidance and prioritise cooling or containment.	Assuming one general extinguisher has stopped internal thermal runaway.
Re-ignition or spread	Withdraw, cool boundaries, establish fire main and seek external assistance.	Using all portable agents without preserving escape and abandonment options.

**WITHDRAW BEFORE
THE ROUTE IS LOST**

Increasing smoke, heat, flame spread, depleted agent or uncertain fuel should trigger withdrawal and escalation rather than a closer approach.

TESTING AND DEMONSTRATION

Inspecting portable units and testing fixed-system functions safely

Owner checks are primarily visual and functional at approved controls. Fixed cylinders, release mechanisms, pipework and suppression sequences require competent servicing and carefully controlled simulation.



Test	What it demonstrates	Limitations / owner focus
Portable visual check	Shows unit location, type, gauge or indicator, pin or seal, hose and corrosion condition.	Does not prove internal agent condition or discharge performance.
Weight or pressure verification	Confirms agent quantity within manufacturer limits.	Temperature and agent type affect interpretation; specialist service may be required.
Fire-blanket check	Confirms accessible, intact container and deployable tabs.	Do not repeatedly deploy in a way that damages or contaminates it.
Fixed-system alarm test	Verifies detection or release alarms, sounders and indication.	Does not discharge agent or prove nozzle distribution.
Shutdown or interlock simulation	Shows fuel, fans, dampers and electrical functions respond.	Use approved specialist cause-and-effect procedure and preserve vessel control.
Cylinder, pipe and nozzle service	Confirms container condition, agent quantity, release head, pipework and nozzles.	Requires approved service methods, intervals and records.

**DO NOT IMPROVISE A
FIXED-SYSTEM TEST**

Pulling a release pin, disconnecting a pressure switch or bridging an interlock can cause accidental discharge or leave the system disabled.

MAINTENANCE STRATEGY

Keeping firefighting equipment visible, suitable and serviceable

Maintenance should preserve correct agent selection, access, pressure or weight, cylinder integrity, distribution, release controls, shutdowns and records.

Area	Good maintenance evidence	Why it matters
Portable extinguishers	Correct type and location, secure bracket, pin or seal, hose, gauge or weight, corrosion and service.	Keeps the first-response tool ready and identifiable.
Fire blankets	Intact pack, accessible position, clean or dry condition and correct size.	Supports immediate cooking or clothing-fire response.
Fixed cylinders or generators	Pressure or mass, corrosion, mounting, valve or release head and temperature exposure.	Ensures designed agent quantity remains available.
Pipework and nozzles	Secure, clear, corrosion-free and protected from paint or refit obstruction.	Preserves agent distribution throughout the space.
Release and alarms	Stations, guards or seals, delays, sounders, panel supply and indication tested.	Supports evacuation and reliable activation.
Space and shutdowns	Protected volume, openings, dampers, fuel or electrical shutdowns and signage reviewed.	Maintains suppression concentration and limits escalation.

Owner-level routine

- Keep every extinguisher and release station unobstructed and visible.
- Check service dates without relying on the date alone; inspect physical condition routinely.
- Review agent suitability after machinery, battery, galley or accommodation changes.
- Confirm fixed-system cylinder weight or pressure and protected volume after refit.
- Investigate every panel fault, discharged unit, missing pin or damaged seal immediately.

WORK TO REFER	Discharge testing, cylinder filling, pressure testing, fixed-system programming, pipe or nozzle service and statutory or coding certification should be completed by approved competent technicians.
---------------	--

RECORDS, SPARES AND SUPPORTABILITY

Knowing what equipment is fitted and how it will be supported

Firefighting equipment should be documented by exact agent, rating, size, location, service provider and replacement path. Generic descriptions such as “engine-room gas system” are not enough.

Area	Useful evidence or provision	Why it matters
Fire-control plan	Locations, agent types, fixed systems, releases, shutdowns and escape routes.	Supports rapid selection and coordinated response.
Portable inventory	Exact type or rating, serial, location, service and replacement date.	Prevents missing or unsuitable units being overlooked.
Fixed-system certificate	Protected volume, agent mass, cylinder data, nozzles, release and service results.	Shows whether the installed system still matches the space.
Agent or service availability	Approved technician, refill source, cylinder transport and legal status.	Important when cruising beyond the original service region.
Selected consumables	Approved seals, pins, signage, brackets or detector or release parts where permitted.	Supports minor restoration without unsafe substitution.
Training and drill record	Crew familiarisation, station operation, decision points and lessons.	Improves correct use under stress.

Practical onboard provision

- Current fire-control plan and extinguisher inventory.
- Agent-specific user instructions and fixed-system release sequence at the station.
- Service certificates, cylinder weights or pressures and protected-volume calculation.
- Suitable protective gloves, lighting and communications for first response.
- Specialist contacts for fixed systems, cylinders, alarms and replacement agents.

SERVICEABILITY IS PART OF OFFSHORE READINESS	An obsolete agent or cylinder that cannot be transported, refilled or legally serviced in the cruising region creates a future protection gap.
--	--

BUYER AND SURVEY PERSPECTIVE

Assessing suitability, integration and service history

A buyer should confirm not only the number of extinguishers but their suitability, location, service condition and integration with detection, shutdown and protected-space arrangements.

Area	Questions or evidence
Portable coverage	Do agent type, rating and location match galley, machinery, electrical, accommodation and deck hazards?
Access and escape	Can each unit be reached from a safe approach without moving toward the likely fire?
Fixed protected space	Does the current volume, openings and machinery arrangement match the suppression design?
Agent and cylinders	Are quantity, pressure or weight, service life, corrosion and refill support documented?
Release and interlocks	Do alarms, delays, fuel or fan shutdowns and dampers work as intended?
Detection and monitoring	Are detector zones, panel faults, remote alarms and power supplies reliable?
Records and compliance	Do service certificates and flag or coding requirements match the current vessel use?

Evidence worth requesting

- Current fire-control plan and portable-equipment schedule.
- Fixed-system design or certificate and protected-volume calculation.
- Cylinder pressure or weight and service records.
- Functional test results for alarms, dampers and shutdowns.
- Details of agent refill or replacement availability.

RECENTLY SERVICED IS NOT THE WHOLE ANSWER

A service sticker does not prove the agent suits the hazard, the fixed system matches the modified space or the crew can reach and use the equipment.

OFFSHORE READINESS

Questions before relying on firefighting equipment offshore

A ready installation provides the right agent at the right location, a fixed system matched to its protected space and a crew that knows when to attack, withdraw and release.

Area	Question to resolve
Hazard match	Which agent is intended for each galley, machinery, electrical and accommodation risk?
Access	Can equipment and release stations be reached from a safe side of the fire?
Fixed system	Is the protected volume sealed and are fuel or ventilation shutdowns integrated?
Condition	Are agent quantity, cylinder condition, gauges, seals, hoses and nozzles current?
Backup	What fire-main, portable and boundary-cooling options remain after fixed-agent release?
Crew response	Can more than one person select, operate and escalate correctly?

Quick readiness check

	Readiness statement
☐	I can identify every portable unit, agent type, fixed release and protected space.
☐	Portable equipment matches the likely hazards and remains accessible from escape routes.
☐	Fixed-system agent quantity and protected volume are current and documented.
☐	Pre-discharge alarms, fuel or fan shutdowns and dampers have been functionally tested.
☐	There are no missing, discharged, corroded, obstructed or out-of-service units.
☐	The crew understand the limits and hazards of water, foam, powder, CO2 and gaseous agents.
☐	Boundary cooling, re-ignition monitoring and fire-main backup are planned.
☐	Service certificates, fire plan, training and specialist contacts are available.

KEY TAKEAWAY

Dependable firefighting equipment combines suitable agents, safe access, correct protected-space design, reliable shutdowns and alarms, current servicing and disciplined crew decisions.

Guidance to consult

Use the current vessel fire-control plan and the installed extinguisher, fixed-suppression, detection and shutdown manufacturers' instructions, together with applicable flag-state, coding, class, insurer and approved service requirements.

Understanding Yacht Systems

Practical guides for owners, buyers
and offshore cruising crews.

AMTG-033

Understanding Fixed and Portable Firefighting Equipment

RELATED GUIDES

AMTG-006 Understanding Fire Detection and Suppression Systems

AMTG-031 Understanding Fire Pumps and Fire Mains

AMTG-032 Understanding Emergency Shutdown Systems

AMTG-034 Understanding Emergency Power Systems

AMTG-026 Understanding Monitoring and Alarm Systems

AMTG-029 Understanding Watertight Integrity

ABOUT ABSOLUTE MARINE

Independent technical advice for explorer yacht owners,
buyers and offshore cruising yacht owners.

Survey Report Reviews | Offshore Readiness Reviews
Reliability | Risk | Readiness

absolute-marine.co.uk

info@absolute-marine.co.uk